

Message 001

Communication from the Commission - TRIS/(2026) 0364

Directive (EU) 2015/1535

Notification: 2026/0057/EE

Notification of a draft text from a Member State

Notification – Notification – Notifizierung – Нотификация – Oznámení – Notifikation – Γνωστοποίηση – Notificación – Teavitamine – Ilmoitus – Obavijest – Bejelentés – Notifica – Pranešimas – Paziņojums – Notifika – Kennisgeving – Zawiadomienie – Notificação – Notificare – Oznámenie – Obvestilo – Anmälan – Fógra a thabhairt

Does not open the delays - N'ouvre pas de délai - Kein Fristbeginn - Не се предвижда период на прекъсване - Nezahtuje prodlení - Fristerne indledes ikke - Καμμία έναρξη προθεσμίας - No abre el plazo - Viivituste perioodi ei avata - Määräaika ei ala tästä - Ne otvara razdoblje kašnjenja - Nem nyitja meg a késésekét - Non fa decorrere la mora - Atidējimai nepradedami - Atlikšanas laikposms nesākas - Ma jiftaħ il-perijodi ta' dewmien - Geen termijnbegin - Nie otwiera opóźnień - Não inicia o prazo - Nu deschide perioadele de stagnare - Nezačína oneskorenia - Ne uvaja zamud - Inleder ingen frist - Ní osclaíonn sé na moilleanna

MSG: 20260364.EN

1. MSG 001 IND 2026 0057 EE EN 05-02-2026 EE NOTIF

2. Estonia

3A. Majandus- ja Kommunikatsiooniministeerium, ettevõtluskeskkonna ja tööstuse osakond, ettevõtluskeskkonna talitus

Suur-Ameeria 1, 10122 Tallinn.

karl.stern@mkm.ee

3B. Kliimaministeerium, aadress Suur-Ameerika 1, 10122 Tallinn

Veeosakond

4. 2026/0057/EE - S00E - ENVIRONMENT

5. Amendment of Regulation No ... of the Minister for Infrastructure on ... 'Requirements and procedure for the construction of wells, bored exits and dug exits'

6. The purpose of the regulation is to contribute to the preservation of good groundwater quality by setting requirements for the construction and design of wells and bore exits.

7.

8. Paragraph 7, as amended, sets out the conditions to be complied with when constructing a well.

Paragraph 7(1) stipulates that when constructing a well, the final jacketed pipe shall only be installed after the bored exit has been drilled in its entirety. The requirement is necessary in order to ensure that the wall of the bored exit is maintained until the end of cementation during the construction of the well.

Paragraph 7(2) states that if a temporary guide pipe has been used during drilling, it must be removed no later than during the installation and cementing of the final jacketed pipe.

Pursuant to Section 7(3), the diameter of the bore exit must be at least 50 mm larger than the outer diameter of the jacketed pipe throughout the entire length of the jacketed pipe in order to ensure a continuous watertight insulation layer of cement material between the jacketed pipe and the bore exit wall.

9. The proposed legislation lays down conditions for drilling technologies in the construction of wells and geothermal wells so as to prevent pollution and deterioration of groundwater quality originating in the ground. When a well is constructed, the pipe remains in the ground, and the cement is poured around the pipe, but this does not always ensure the insulation of the water layers, and the water layers may mix with each other, and the influx of rainwater or surface water into the well is not excluded. The mixing of water layers or the inflow of rainwater or surface water into deep groundwater layers may contaminate groundwater and deteriorate its quality.

10. References to related legislation: There is no related legislation

11. No

12.

13. No

14. No

15. Yes

16.

TBT aspects: No

SPS aspects: No

European Commission

Contact point Directive (EU) 2015/1535

email: grow-dir2015-1535-central@ec.europa.eu