

DRAFT of the 8th amendment to the revised version of xx.xx.2026

ASSESSMENT BASIS

Assessment basis for metal materials in contact with drinking water^{1,2}

DRAFT

¹ Notified in accordance with Directive (EU) 2015/1535 of the European Parliament and of the Council, of 9 September 2015, laying down a procedure for the provision of information in the field of technical regulations and of rules on Information Society services (OJ L 241, 17/9/2015, p. 1).

² Notified under 2026/xxx/D

Amendments

The following amendments are to be made:

- I. In Chapter 1, the first sentence of Paragraph 11 is replaced by the following: “The following metal materials may no longer be contained in products newly installed in water supply systems from 12 January 2028, (numbering according to the Annex Positive List of metal materials suitable for drinking water hygiene):”
- II. In Point 2.8.1 of the Annex, the category limits are amended as follows:
 - a) The lower limit for Cu is replaced by ≥ 57.0 % (m/m).
 - b) The lower limit for Sn is replaced by 0.3 % (m/m).
 - c) The upper limit for Fe is replaced by ≤ 0.2 % (m/m).
- III. In the Annex, the material CW730R-DW (CuZn41Sn1P) is added as a new Point 2.8.3.2 of Point 2.8:

2.8.3.2 CW730R-DW (CuZn41Sn1P)

Designation	Product group
CW730R-DW* (CuZn41Sn1P)	B - D

Alloy constituents (% (m/m)):

Cu	Zn	Sn	P
57,0 % - 59,0 %	Rest	0,3 % - 1,0 %	0,05 % - 0,1 %

Unavoidable accompanying elements (% (m/m)):

Al	Fe	Ni*	Pb	Si
$\leq 0,05$ %	$\leq 0,2$ %	$\leq 0,03$ %	$\leq 0,10$ %	$\leq 0,10$ %